


NOTE:

ALL TAPPING SLEEVES SHALL BE WRAPPED WITH TWO LAYERS OF 20MIL. PIPE TAPE AND ENCASED IN 8MIL. POLYETHYLENE WITH SEAMS SEALED WITH 2" WIDE SCOTCHRAP #50 OR CITY APPROVED EQUAL.

DATE	BY	(REVISIONS) DESCRIPTION

APPROVED:  DIRECTOR OF PUBLIC WORKS/CITY ENGINEER R.C.E. 47907 10/30/02 DATE	CITY OF LOMA LINDA	STANDARD DRAWING NO. W-16
	4" TO 10" TAPPING SLEEVE	